

# Water Sampling Log

Name of Building Holland Township School  
 Building Owner Holland Township Bd of Educ

Date Collected 25-Apr-17  
 Sample Collected by PD McGuinness

Sample No.	Tap No.	Sample Type	Type of Outlet	Manufacturer	Sample Location	Time	Results (mg/L)	
							Cu	Pb
042517-01	1	1st	Chiller	Halsey Taylor	Front Main Hallway - near Girls' restroom	06:19	0.10	ND
042517-02	2	1st	Chiller	SunRoc	CST Hallway - near Art Room	06:21	0.13	0.023
042517-03	3	1st	Chiller	Oasis	CST Hallway - near Room #19	06:23	0.11	ND
042517-04	4	1st	Chiller	Oasis	5 & 6th grade hall near boys restroom	06:25	0.19	ND
042517-05	5	1st	Ceramic Bubbler	Halsey Taylor	5 & 6th grade hall near girls restroom	06:27	0.10	0.0048
042517-06	6	1st	Chiller	Halsey Taylor	7th grade hall near room #49	06:28	0.16	ND
042517-07	7	1st	Chiller	Oasis	8th grade hall near boys & girls restroom	06:30	0.26	ND
042517-08	8	1st	Ceramic Bubbler	Halsey Taylor	8th grade hall near room #54	06:32	0.14	ND
042517-09	9	1st	unknown		Kindergarten hall across from staff restrooms	06:34	0.11	0.0030
042517-10	10	1st	unknown		Kindergarten hall across from staff restrooms	06:35	0.10	0.0051
042517-11	11	1st	Chiller	Oasis	1st & 2nd grade hall near boys restroom	06:37	0.097	ND
042517-12	12	1st	Chiller	Oasis	3rd & 4th grade hall near staff room	06:39	0.21	ND
042517-13	13	1st	unknown		Front main hall room #1	06:40	0.16	0.0047
042517-14	14	1st	Sink		Board Office	06:48	0.11	0.0031
042517-15	15	1st	Sink		Main middle school kitchen	06:49	0.14	0.0046
042517-16	16	1st	Sink		Staff room off auditorium	06:51	0.089	0.0021
042517-17	17	1st	kitchen sink		CST office suite	06:52	0.10	0.0020
042517-18	18	1st	Sink		CST Hall-recycle room	06:52	0.13	ND
042517-19	19	1st	Sink		8th grade hall room #55	06:54	0.15	0.0038
042517-20	20	1st	Sink		8th grade hall room #53	06:55	0.13	0.0027

Sample Type: **1st:** First Draw sample collected after water sat in pipe between 8 and 18 hours

**FL:** Water flushed through tap for at least 2 minutes

**ND:** means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0020 mg/L for Lead.

# Water Sampling Log

Name of Building Holland Township School  
 Building Owner Holland Township Bd of Educ

Date Collected 25-Apr-17  
 Sample Collected by PD McGuinness

Sample No.	Tap No.	Sample Type	Type of Outlet	Mfg/Model Serial No.	Sample Location	Time	Results (mg/L)	
							Cu	Pb
042517-21	21	1st	Bubbler		Kindergarten hall room #A-1 (low flow)	06:57	0.16	ND
042517-22	22	1st	Bubbler		Kindergarten hall room #A-2	06:58	0.16	0.0025
042517-23	23	1st	Bubbler		Kindergarten hall room #A-3	06:58	0.10	ND
042517-24	24	1st	Unknown		Kindergarten hall staff room	07:00	0.19	0.0041
042517-25	25	1st	Sink		1st & 2nd grade hall nurses room	07:01	0.16	0.0062
042517-26	26	1st	Bubbler		1st & 2nd grade hall room #A-4	07:03	0.14	0.0050
042517-27	27	1st	Bubbler		1st & 2nd grade hall room #A-5 (low flow)	07:04	0.17	0.0062
042517-28	28	1st	Bubbler		1st & 2nd grade hall room #A-6	07:05	0.13	0.0086
042517-29	29	1st	Bubbler		1st & 2nd grade hall room #A-7	07:07	0.13	0.0032
042517-30	30	1st	Bubbler		1st & 2nd grade hall room #A-8	07:08	0.12	ND
042517-31	31	1st	Bubbler		1st & 2nd grade hall room #A-9	07:09	0.12	0.0038
042517-32	32	1st	Bubbler		1st & 2nd grade hall room #A-10	07:10	0.11	0.0028
042517-33	33	1st	Bubbler		1st & 2nd grade hall room #A-11	07:10	0.11	ND
042517-34	34	1st	Bubbler		1st & 2nd grade hall room #A-12	07:11	0.14	0.0039
042517-35	35	1st	Bubbler		Room 50	07:14	0.16	ND
042517-36	36	1st	Bubbler		3rd & 4th grade hall room #A-21	07:15	0.17	0.0028
042517-37	37	1st	Bubbler		3rd & 4th grade hall room #A-22	07:17	0.12	0.0020
042517-38	38	1st	Bubbler		3rd & 4th grade hall room #A-23 (low flow)	07:19	0.14	0.0034
042517-39	39	1st	Bubbler		3rd & 4th grade hall room #A-25	07:20	0.11	ND
042517-40	40	1st	Bubbler		3rd & 4th grade hall room #A-26	07:21	0.11	ND

Sample Type: **1st:** First Draw sample collected after water sat in pipe between 8 and 18 hours

**FL:** Water flushed through tap for at least 2 minutes

**ND:** means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0020 mg/L for Lead.

# Water Sampling Log

Name of Building Holland Township School  
 Building Owner Holland Township Bd of Educ

Date Collected 25-Apr-17  
 Sample Collected by PD McGuinness

Sample No.	Tap No.	Sample Type	Type of Outlet	Mfg/Model Serial No.	Sample Location	Time	Results (mg/L)	
							Cu	Pb
042517-41	41	1st	Bubbler		3rd & 4th grade hall room #A-27	07:22	0.15	0.0036
042517-42	42	1st	Bubbler		3rd & 4th grade hall room #A-28	07:24	0.16	0.0035
042517-43	43	1st	Bubbler		3rd & 4th grade hall room #A-29	07:25	0.14	ND
042517-44	44	1st	Bubbler		3rd & 4th grade hall room #A-30	07:26	0.15	ND
042517-45	45	1st	Bubbler		3rd & 4th grade hall room #A-31	07:27	0.13	0.0047
042517-46	46	1st	Sink		3rd & 4th grade hall staffroom	07:27	0.14	ND

Sample Type: **1st:** First Draw sample collected after water sat in pipe between 8 and 18 hours  
**FL:** Water flushed through tap for at least 2 minutes  
**ND:** means Not Detected at or above the Reliability Detection Limit (RDL) of 0.0020 mg/L for Lead.